

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1263

Dated: 01-02-2024

It is certified that an inspection team headed by General Purohit

(Name of Officers with designation) from S.I. Sector No-4

(Name of Department/ Office) inspected the NAGAR NIGAM Kute Harth

(Name & Address of the school) on 31-01-2024 (date of inspection) and found that the **BSN ACADEMY, NANTA (KUNARI), KOTA (RAJASTHAN)** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal: [Signature]

Name

TANUJ K. SHARMA

Designation

Health Officer

Name & Address of the Office / Department : .....

To

BSN ACADEMY  
NANTA (KUNARI), KOTA  
RAJASTHAN

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**OFFICE OF THE SENIOR CHEMIST**  
**Public Health Engineering Department Regional Laboratory**

AKELGARH KOTA-324010 (Raj.)

**REPORT OF THE CHEMICAL EXAMINATION OF WATER**

PHED/Sr. Chemist/Lab Chem / 2023-2024 / 2657-58

To: Sirish Vijay  
Kota

Date: 19-01-24

District: Kota

Tehsil: Ladpura

Ref. :- Your letter No. NM Dated 10-01-24

Date of Receipt: 10-01-24

Date of Collection: 10-01-24

Name of Sample Taker: Sri Girish Vijay


Code No.	U			
Particulars of Source	<u>BGM Academy</u>			
Source	<u>BT-500 School Nanda Kola</u>			
Village/Town	<u>T/W</u>			
Lab Ref No.	<u>Kota</u>			
	<u>PC-174</u>			
Note :- ALL Results Except pH are In mg				
<b>PHYSICAL EXAMINATION</b>				
1- pH	<u>8.49</u>			
2- Turbidity (NTU)	<u>4.8</u>			
3- Colour	<u>ND</u>			
4- Odour	<u>UO</u>			
<b>CHEMICAL EXAMINATION</b>				
1- Alkalinity Phenolphthalein (CaCO <sub>3</sub> )	<u>-</u>			
2- Alkalinity Methyl Orange (CaCO <sub>3</sub> )	<u>80</u>			
3- Total Hardness (CaCO <sub>3</sub> )	<u>150</u>			
4- Calcium Hardness (CaCO <sub>3</sub> )	<u>40</u>			
5- Magnesium Hardness (as CaCO <sub>3</sub> )	<u>110</u>			
6- Chlorides (as Cl <sup>-</sup> )	<u>40</u>			
7- Sulphate (as SO <sub>4</sub> <sup>2-</sup> )	<u>4</u>			
8- Nitrites (as NO <sub>2</sub> )	<u>-</u>			
9- Nitrates (as NO <sub>3</sub> )	<u>0.84</u>			
10- Conductivity	<u>-</u>			
11- Total Dissolved Solids	<u>248</u>			
12- Residual Chlorine	<u>-</u>			
13- Fluoride	<u>0.52</u>			
14-				
15-				
16-				

Remarks :-

Date

PHED/Sr. Chemist/Lab./Chem/2023-2024/

- (1) Copy Submitted to Chief Chemist, P.H.E.D. Lab Jaipur, for information.
- (2) Copy to EXEN. PHED.....
- (3) Copy to.....

  
 Senior Chemist  
 P.H.E.D. Regional Lab Kota  
  
 Senior Chemist  
 P.H.E.D. Regional Lab Kota



**OFFICE OF THE SENIOR CHEMIST**  
**Public Health Engineering Department Regional Laboratory**  
**AKELGARH KOTA-324010 (Raj.)**  
**BACTERIOLOGICAL EXAM. REPORT**

PHED/Lab/Sr.Chemist/Bact/20 23 - 2024/2657-58

Date : 19.01.24

To,  
 The Shri Girish Vijay.  
Kota

Tehsil : Ladpura

District : Kota

Village : Kota

Code No. U

Reference N/M 10.01.24

Name of the Sample Taker.....

Lab Sample Number	Date & Time of Collection	Date of Exam.	Residual Chlorine Mg/l	Source	PARTICULARS OF SAMPLE	Coliform organism MNP/100 ml.	E coli organism MNP/100 ml.
PB-276	10.1.24	10.1.24	—	T/W	BSN Academy Sr. Sec. School, Mantā, Kōtā	nil	

PHED/Lab/Sr. Chemist / Bact / 2023.... - 2024....

Date

- Copy To :
1. The Chief Chemist, PHED Raj. Jaipur
  2. ....
  3. ....
  4. ....

  
 ✓ Senior Chemist

P.H.E.D. Regional Lab Kota

Senior Chemist

P.H.E.D. Regional Lab Kota